

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4075-1537:100 Page 1 of 1

CATEGORY: Glazing/Window Assemblies

LISTING: InterEdge Technologies, 27 Central Avenue, Sausalito, CA 94965
Contact: Scott Foote (415) 331-6379 Fax (415) 289-0326

DESIGN: Model PyroEdge 20, 1/4" and 3/8" thick fire-rated glazing material. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-Minute
Thickness: 1/4" and 3/8"

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type, classification, ITS/Warnock Hersey label.

APPROVAL: Listed as fire-rated glazing material for use in 20-minute listed doors and sidelights. Glazing is manufactured to order and cannot be trimmed or cut to a different size without destroying the glazing.

11-15-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager